



# CAPE COD COMMISSION

3225 MAIN STREET  
P.O. BOX 226  
BARNSTABLE, MA 02630  
(508) 362-3828  
FAX (508) 362-3136

E-mail: [frontdesk@capecodcommission.org](mailto:frontdesk@capecodcommission.org)

DATE: June 5, 2000

TO: Patrick Butler, Esq.  
Nutter, McClennen & Fish  
1630 Falmouth Road  
P.O. Box 1630  
Hyannis, MA 02601

FROM: Cape Cod Commission

RE: Modification of Development of Regional Impact Decision dated  
March 30, 1994 and modified November 3, 1994, and October 6,  
1997

Cape Cod Commission Act, Sections 12 and 13

APPLICANT: Carol Levy, CEO  
Rehabilitation Hospital for the Cape & Islands, Inc.  
116 Route 6A  
Sandwich, MA 02563

PROJECT: Rehabilitation Hospital for the Cape & Islands, Inc.

PROJECT #: TR93025

BOOK/PAGE: Book 462, Page 28  
Book 6772, Page 60  
Book 9468, Page 22 (original decision)

---

## **MODIFICATION TO DEVELOPMENT OF REGIONAL IMPACT DECISION**

The Development of Regional Impact decision dated March 30, 1994 and modified November 3, 1994 and October 6, 1997 for the Rehabilitation Hospital for the Cape & Islands, Inc. (RHCI) is hereby amended by a vote of the Regulatory Committee on June 5, 2000 by adding the following conditions:

27. The wastewater treatment system shall be designed to replace the existing system for a 60-bed rehabilitation hospital, with a design flow of 12,000 gallons per day.

28. For a period of eighteen months, starting when the new system is operational, condition 11 of the original DRI dated March 30, 1994 and 25 of the October 6, 1997 modification shall be replaced with the following conditions:


- a. Water quality effluent sampling shall be completed following the schedule and parameters determined by DEP's pilot system approval dated December 9, 1999.
- b. Maximum effluent concentration discharged from the Amphidrome system for Total nitrogen shall not exceed 5.00 ppm. Total nitrogen approximates the sum of Total Kjeldahl nitrogen and nitrate nitrogen.

29. In order to track water quality improvements on-site, MW-4 shall continue to be monitored for nitrate-nitrogen, ammonia, total nitrogen, specific conductance and alkalinity on a quarterly basis.


30. Copies of water quality analysis shall be forwarded to the Cape Cod Commission and the Sandwich Board of Health on a quarterly basis.

31. At the end of the eighteen-month piloting period quarterly monitoring shall be resumed as required in the original decision and modification dated October 6, 1997. Based on a review of the water quality by CCC and the Sandwich BOH, the sampling program may be revised.

32. Any additions or alterations to the original project that will increase wastewater flows will require a DEP groundwater discharge permit, and the applicant shall notify the Cape Cod Commission of such.



Robert D. Deane, Chair




Date

Commonwealth of Massachusetts

Barnstable, ss.

Subscribed and sworn to before me this 22<sup>nd</sup> day of June 19~~20~~00



Name, Notary Public

My commission expires:

